

ASME BPVC.III.1.NB-2025

SECTION III

Rules for Construction of
Nuclear Facility Components

2025

ASME Boiler and
Pressure Vessel Code
An International Code

Division 1 — Subsection NB
Class 1 Components



Markings such as “ASME,” “ASME Standard,” or any other marking including “ASME,” ASME logos, or the ASME Single Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code or Standard. Use of the ASME Single Certification Mark requires formal ASME certification; if no certification program is available, such ASME markings may not be used. (For Certification and Accreditation Programs, see <https://www.asme.org/certification-accreditation>.)

Items produced by parties not formally possessing an ASME Certificate may not be described, either explicitly or implicitly, as ASME certified or approved in any code forms or other document.

AN INTERNATIONAL CODE

2025 ASME Boiler & Pressure Vessel Code

2025 Edition

July 1, 2025



RULES FOR CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS

Division 1 - Subsection NB

Class 1 Components

ASME Boiler and Pressure Vessel Committee
on Construction of Nuclear Facility Components



The American Society of
Mechanical Engineers

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: July 1, 2025

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark



ASME Single Certification Mark

All rights reserved. “ASME” and the above ASME symbols are registered trademarks of The American Society of Mechanical Engineers. No part of this document may be copied, modified, distributed, published, displayed, or otherwise reproduced in any form or by any means, electronic, digital, or mechanical, now known or hereafter invented, without the express written permission of ASME. No works derived from this document or any content therein may be created without the express written permission of ASME. Using this document or any content therein to train, create, or improve any artificial intelligence and/or machine learning platform, system, application, model, or algorithm is strictly prohibited.

Library of Congress Catalog Card Number: 56-3934

Adopted by the Council of The American Society of Mechanical Engineers, 1914; latest edition 2025.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2025 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

TABLE OF CONTENTS

List of Sections	vii
Foreword	viii
Statement of Policy on the Use of the ASME Single Certification Mark and Code Authorization in Advertising	x
Statement of Policy on the Use of ASME Marking to Identify Manufactured Items	x
Personnel	xi
Correspondence With the Committee	xxxiv
Organization of Section III	xxxvi
Summary of Changes	xl
Cross-Referencing in the ASME BPVC	xli
Article NB-1000	
NB-1100	
Article NB-2000	
NB-2100	
NB-2200	
NB-2300	
NB-2400	
NB-2500	
NB-2600	
NB-2700	
Article NB-3000	
NB-3100	
NB-3200	
NB-3300	
NB-3400	
NB-3500	
NB-3600	
Article NB-4000	
NB-4100	
NB-4200	
NB-4300	
NB-4400	
NB-4500	
NB-4600	
NB-4700	
Article NB-5000	
NB-5100	
NB-5200	
Introduction	1
Scope	1
Material	7
General Requirements for Material	7
Material Test Coupons and Specimens for Ferritic Steel Material	10
Fracture Toughness Requirements for Material	12
Welding Material	16
Examination and Repair of Pressure-Retaining Material	20
Material Organizations' Quality System Programs	36
Dimensional Standards	36
Design	37
General Design	37
Design by Analysis	42
Vessel Design	42
Pump Design	55
Valve Design	60
Piping Design	87
Fabrication and Installation	125
General Requirements	125
Forming, Fitting, and Aligning	126
Welding Qualifications	132
Rules Governing Making, Examining, and Repairing Welds	149
Brazing	157
Heat Treatment	159
Mechanical Joints	167
Examination	168
General Requirements for Examination	168
Required Examination of Welds for Fabrication and Preservice Baseline	170

NB-5300	Acceptance Standards	173
NB-5400	Final Examination of Vessels	175
NB-5500	Qualifications and Certification of Nondestructive Examination Personnel	175
Article NB-6000	Testing	177
NB-6100	General Requirements	177
NB-6200	Hydrostatic Tests	178
NB-6300	Pneumatic Tests	179
NB-6400	Pressure Test Gages	180
NB-6600	Special Test Pressure Situations	180
Article NB-7000	Overpressure Protection	181
NB-7100	General Requirements	181
NB-7200	Overpressure Protection Report	183
NB-7300	Relieving Capacity	184
NB-7400	Set Pressures of Pressure Relief Devices	185
NB-7500	Operating and Design Requirements for Pressure Relief Valves	185
NB-7600	Nonreclosing Pressure Relief Devices	189
NB-7700	Certification	190
NB-7800	Marking, Stamping With Certification Mark, and Data Reports	190
Article NB-8000	Nameplates, Stamping With Certification Mark, and Reports	192
NB-8100	General Requirements	192
Figures		
NB-1132.2-1	Attachments in the Component Support Load Path That Do Not Perform a Pressure-Retaining Function	3
NB-1132.2-2	Attachments That Do Not Perform a Pressure-Retaining Function and Are Not in the Component Support Load Path (Nonstructural Attachments)	4
NB-1132.2-3	Attachments That Perform a Pressure-Retaining Function	5
NB-1132.2-4	Attachments Within the Reactor Pressure Vessel (Core Support Structures) That Do Not Perform a Pressure-Retaining Function	6
NB-2433.1-1	Weld Metal Delta Ferrite Content	20
NB-2552-1	Axial Propagation of Sound in Tube Wall	26
NB-2575.2-1	Typical Pressure-Retaining Parts of Pumps and Valves	33
NB-3332.2-1	Chart for Determining Value of F	44
NB-3338.2(a)-1	Direction of Stress Components	46
NB-3338.2(a)-2	Nozzle Dimensions	47
NB-3339.1(b)-1	Examples of Acceptable Transition Details	49
NB-3339.4-1	Limits of Reinforcing Zone	51
NB-3351-1	Welded Joint Locations Typical of Categories A, B, C, and D	52
NB-3352-1	Typical Butt Joints	53
NB-3361-1	Category A and B Joints Between Sections of Unequal Thickness	54
NB-3423-1	Typical Single Volute Casing	56
NB-3423-2	Typical Double Volute Casing	56
NB-3433.4-1	Minimum Tangential Inlet and Outlet Wall Thickness	57
NB-3441.1-1	Type A Pump	58

NB-3441.1-2	Type A Pump	58
NB-3441.2-1	Type B Pump	58
NB-3441.3-1	Type C Pump	58
NB-3441.3-2	Type C Pump	59
NB-3441.4(a)-1	Type D Pump	60
NB-3441.5-1	Type E Pump	60
NB-3441.6(a)-1	Type F Pump	60
NB-3441.7-1	Typical Type M Pump With Volute Case	61
NB-3441.7-2	Typical Type M Pump, Integral to Vessel	62
NB-3544.1(a)-1	Filletts and Corners	69
NB-3544.1(c)-1	Ring Grooves	69
NB-3544.3-1	Lugs and Protuberances	70
NB-3544.7-1	Flat Wall Limitation	70
NB-3545.1(a)-1	Pressure Area Method	72
NB-3545.2(a)-1	Critical Sections of Valve Bodies	75
NB-3545.2(c)-1	Model for Determining Secondary Stress in Valve Crotch Region	77
NB-3545.2(c)-3	Thermal Stress Index Versus Thickness Continuity Run or Branch . .	78
NB-3545.2(c)-4	Secondary Stress Index Versus Thickness Discontinuity Run or Branch	79
NB-3545.2(c)-5	C_4 Versus T_{e1}/t_e	80
NB-3545.2(c)-6	Stress Index for Thermal Fatigue	80
NB-3591.2-1	Typical Pressure Relief Devices	83
NB-3591.2-2	Typical Pressure Relief and Safety Relief Devices	84
NB-3594.3-1	Valve Nozzle	86
NB-3622.2-1	Examples of Reversing and Nonreversing Dynamic Loads	89
NB-3643.3(a)-1	Branch Connection Nomenclature	94
NB-3643.3(a)-2	Typical Reinforcement of Openings	95
NB-3643.3(a)-3	Typical Reinforced Extruded Outlet	96
NB-3644(b)-1	Miter Joint Geometry	98
NB-3647.2-1	Types of Permanent Blanks	99
NB-3653.2(b)-1	Decomposition of Temperature Distribution Range	103
NB-3683.1(c)-1	112
NB-3683.1(d)-1	113
NB-3683.6-1	115
NB-3684-1	Direction of Stress Components	118
NB-3685.2-1	Elbow Nomenclature	121
NB-3686.1-1	122
NB-3686.2-1	122
NB-3686.5-1	Branch Connections in Straight Pipe	124
NB-3686.6-1	Reducers	124
NB-4221.1-1	Maximum Difference in Cross-Sectional Diameters	128
NB-4221.2(a)-1	Maximum Permissible Deviation e From a True Circular Form	128
NB-4221.2(a)-2	Maximum Arc Length for Determining Plus or Minus Deviation	129
NB-4233(a)-1	Butt Weld Alignment and Mismatch Tolerances for Unequal I.D. and O.D. When Components Are Welded From One Side and Fairing Is Not Performed	131

NB-4243-1	Acceptable Full Penetration Weld Details for Category C Joints (NB-3352.3)	133
NB-4244(a)-1	Nozzles Joined by Full Penetration Butt Welds	134
NB-4244(b)-1	Nozzles Joined by Full Penetration Corner Welds	135
NB-4244(c)-1	Deposited Weld Metal Used as Reinforcement of Openings for Nozzles	136
NB-4244(d)-1	Partial Penetration Nozzles	137
NB-4244(d)-2	Partial Penetration Nozzle for Coaxial Cylinders	138
NB-4244(e)-1	Oblique Connections	139
NB-4246(a)-1	Typical Piping Branch Connections Joined by Full Penetration Welds	140
NB-4246(b)-1	Typical Piping Branch Connections Joined by a Fillet Weld or a Partial Penetration Weld	141
NB-4250-1	Welding End Transitions — Maximum Envelope	142
NB-4250-2	Component to Pipe Weld	143
NB-4250-3	Pipe to Pipe Weld	144
NB-4424.2-1	Preservice Examination or MANDE Marking for Piping	152
NB-4427-1	Fillet and Socket Weld Details and Dimensions	153
NB-4433-1	Types of Attachment Welds	155
NB-4440-1	Appurtenance Weld Joint Details, NPS 2 (DN 50) and Smaller	156
NB-4511-1	Brazed Connections for Appurtenances and Piping, NPS 1 (DN 25) and Smaller	158
NB-4622.9(d)-1	Dissimilar Metal Repair Cavity Measurement	166
Tables		
NB-2332(a)-1	Required C_v Values for Piping, Pumps, and Valves	15
NB-2333-1	Required C_v Values for Bolting Material	15
NB-2432.1-1	Sampling of Welding Materials for Chemical Analysis	18
NB-2432.2(a)-1	Chemical Analysis for Reactor Vessel Welding Material	19
NB-2432.2(a)-2	Chemical Analysis for Welding Material for Other Than Reactor Vessel Welds	19
NB-2571-1	Required Examinations	29
NB-3338.2(c)-1	Stress Indices for Nozzles	48
NB-3339.3-1	Required Minimum Reinforcing Area, A_r	50
NB-3339.7(c)-1	Stress Indices for Internal Pressure Loading	51
NB-3641.1(a)-1	Values of A	91
NB-3681(a)-1	Stress Indices for Use With Equations in NB-3650	110
NB-3685.1-1	Curved Pipe or Welding End Elbows, Internal Pressure	119
NB-3685.1-2	Curved Pipe or Welding End Elbows, Moment Loading ($\lambda \geq 0.2$)	120
NB-4232-1	Maximum Allowable Offset in Final Welded Joints	130
NB-4524-1	Maximum Design Temperatures for Brazing Filler Metal	159
NB-4622.1-1	Mandatory Requirements for Postweld Heat Treatment of Welds	161
NB-4622.4(c)-1	Alternative Holding Temperatures and Times	162
NB-4622.7(b)-1	Exemptions to Mandatory PWHT	163
NB-5111-1	Thickness, IQI Designations, Essential Holes, and Wire Diameters	169
Endnotes	193

LIST OF SECTIONS

(25)

SECTIONS

- I Rules for Construction of Power Boilers
- II Materials
 - Part A — Ferrous Material Specifications
 - Part B — Nonferrous Material Specifications
 - Part C — Specifications for Welding Rods, Electrodes, and Filler Metals
 - Part D — Properties (Customary)
 - Part D — Properties (Metric)
- III Rules for Construction of Nuclear Facility Components
 - Subsection NCA — General Requirements for Division 1 and Division 2
 - Appendices
 - Division 1
 - Subsection NB — Class 1 Components
 - Subsection NCD — Class 2 and Class 3 Components
 - Subsection NE — Class MC Components
 - Subsection NF — Supports
 - Subsection NG — Core Support Structures
 - Division 2 — Code for Concrete Containments
 - Division 3 — Containment Systems for Transportation and Storage of Spent Nuclear Fuel and High-Level Radioactive Material
 - Division 4 — Fusion Energy Devices
 - Division 5 — High Temperature Reactors
- IV Rules for Construction of Heating Boilers
- V Nondestructive Examination
- VI Recommended Rules for the Care and Operation of Heating Boilers
- VII Recommended Guidelines for the Care of Power Boilers
- VIII Rules for Construction of Pressure Vessels
 - Division 1
 - Division 2 — Alternative Rules
 - Division 3 — Alternative Rules for Construction of High Pressure Vessels
- IX Welding, Brazing, and Fusing Qualifications
- X Fiber-Reinforced Plastic Pressure Vessels
- XI Rules for Inservice Inspection of Nuclear Reactor Facility Components
 - Division 1 — Rules for Inservice Inspection of Nuclear Power Plant Components
 - Division 2 — Requirements for Reliability and Integrity Management (RIM) Programs for Nuclear Reactor Facilities
- XII Rules for Construction and Continued Service of Transport Tanks
- XIII Rules for Overpressure Protection

FOREWORD*

In 1911, The American Society of Mechanical Engineers established the Boiler and Pressure Vessel Committee to formulate standard rules for the construction of steam boilers and other pressure vessels. In 2009, the Boiler and Pressure Vessel Committee was superseded by the following committees:

- (a) Committee on Power Boilers (I)
- (b) Committee on Materials (II)
- (c) Committee on Construction of Nuclear Facility Components (III)
- (d) Committee on Heating Boilers (IV)
- (e) Committee on Nondestructive Examination (V)
- (f) Committee on Pressure Vessels (VIII)
- (g) Committee on Welding, Brazing, and Fusing (IX)
- (h) Committee on Fiber-Reinforced Plastic Pressure Vessels (X)
- (i) Committee on Nuclear Inservice Inspection (XI)
- (j) Committee on Transport Tanks (XII)
- (k) Committee on Overpressure Protection (XIII)
- (l) Technical Oversight Management Committee (TOMC)

Where reference is made to “the Committee” in this Foreword, each of these committees is included individually and collectively.

The Committee’s function is to establish rules of safety relating to pressure integrity. The rules govern the construction** of boilers, pressure vessels, transport tanks, and nuclear components, and the inservice inspection of nuclear components and transport tanks. For nuclear items other than pressure-retaining components, the Committee also establishes rules of safety related to structural integrity. The Committee also interprets these rules when questions arise regarding their intent. The technical consistency of the Sections of the Code and coordination of standards development activities of the Committees is supported and guided by the Technical Oversight Management Committee. The Code does not address other safety issues relating to the construction of boilers, pressure vessels, transport tanks, or nuclear components, or the inservice inspection of nuclear components or transport tanks. Users of the Code should refer to the pertinent codes, standards, laws, regulations, or other relevant documents for safety issues other than those relating to pressure integrity and, for nuclear items other than pressure-retaining components, structural integrity. Except for Sections XI and XII, and with a few other exceptions, the rules do not, of practical necessity, reflect the likelihood and consequences of deterioration in service related to specific service fluids or external operating environments. In formulating the rules, the Committee considers the needs of users, manufacturers, and inspectors of components addressed by the Code. The objective of the rules is to afford reasonably certain protection of life and property, and to provide a margin for deterioration in service to give a reasonably long, safe period of usefulness. Advancements in design and materials and evidence of experience have been recognized.

The Code contains mandatory requirements, specific prohibitions, and nonmandatory guidance for construction activities and inservice inspection and testing activities. The Code does not address all aspects of these activities and those aspects that are not specifically addressed should not be considered prohibited. The Code is not a handbook and cannot replace education, experience, and the use of engineering judgment. The phrase *engineering judgment* refers to technical judgments made by knowledgeable engineers experienced in the application of the Code. Engineering judgments must be consistent with Code philosophy, and such judgments must never be used to overrule mandatory requirements or specific prohibitions of the Code.

The Committee recognizes that tools and techniques used for design and analysis change as technology progresses and expects engineers to use good judgment in the application of these tools. The designer is responsible for complying with Code rules and demonstrating compliance with Code equations when such equations are mandatory. The Code neither requires nor prohibits the use of computers for the design or analysis of components constructed to the requirements of the Code. However, designers and engineers using computer programs for design or analysis are cautioned that they are

* The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI’s requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Code.

** *Construction*, as used in this Foreword, is an all-inclusive term comprising materials, design, fabrication, examination, inspection, testing, certification, and overpressure protection.